

**Summary of Listing for warringtonfire – mideast  
Listing No. 011**

**Al Huda Interiors 'Timber Based FD30 Doorsets'**

**Scope of Certification**

This Summary has been prepared by warringtonfire and is a summary of the report referenced below. Full details of the constructions, justification for the conclusions given, along with validity statements are given in that report and the supporting test report.

This summary sheet covers single-acting, single-leaf doorsets incorporating an extruded tubeboard core as previously fire tested and assessed by warringtonfire against Clause 6 of BS 476: Part 22: 1987 'Methods for determination of the fire resistance of non-loadbearing elements of construction' up to the maximum sizes as shown.

The doorsets are suitable for **30 minutes integrity and insulation performance**, unless otherwise indicated.

Report Reference	Period of Validity
WFRC No. C149896	Until 1 <sup>st</sup> January 2011

**Table 1 – Maximum Permitted Door Leaf Dimensions**

Configuration	Maximum Leaf Height (mm)	Maximum leaf Width (mm)
Single-Acting, Single-Leaf	2100	900

**Table 2 – Intumescent Specification**

Position	Intumescent Specification
Head	10 mm wide by 2 mm thick (Palusol)
Vertical Edges	10 mm wide by 2 mm thick (Palusol)

<b>Door Frame</b>	130 mm by 30 mm hardwood (minimum density 640 kg/m <sup>3</sup> ) with 15 mm deep rebated stop
<b>Hinges</b>	Mild/stainless steel construction of blade dimensions 100 mm high by 30 mm wide
<b>Lockset</b>	Mild steel tubular mortise latch referenced Dorma 711
<b>Tolerances</b>	All door leaves should be accurately fitted within the frame with an absolute maximum door gap (between the leaf and frame) of 3 mm

*This Summary is based upon a report, as referenced above, prepared by warringtonfire. Full details of the constructions and justification for the conclusions given, along with validity statements, are given in that report.*

*The summary has been compiled between warringtonfire and Al Huda Interiors. It is intended to provide a brief outline of the above referenced report and not to replace it.*

Full copies of the referenced report may be obtained from:

Al Huda Interiors, Musafah 37, Plot No. 161, Industrial Area, Abu Dhabi, U.A.E.

Tel : +971 2 5515066

Fax : +971 2 5515065

**Responsible Officer**  
S Hankey\* - Technical Consultant

**Approved**  
C W Miles\* - Mid-East Product Listing Manager

\* For and on behalf of warringtonfire.