

**Summary of Listing for warringtonfire – mideast
Listing No. 012**

Al Huda Interiors 'Timber Based FD60 Doorsets'

Scope of Certification

This Summary has been prepared by warringtonfire and is a summary of the report referenced below. Full details of the constructions, justification for the conclusions given, along with validity statements are given in that report and the supporting test report.

This summary sheet covers single-acting, single-leaf doorsets incorporating an extruded solidboard core as previously fire tested and subsequently assessed by warringtonfire against Clause 6 of BS 476: Part 22: 1987 'Methods for determination of the fire resistance of non-loadbearing elements of construction' up to the maximum sizes as shown. The doorsets are suitable for **60 minutes integrity and insulation performance**, unless otherwise indicated.

Report Reference	Period of Validity
WFRC No. C149930	Until 1 st January 2011

Table 1 – Maximum Permitted Door Leaf Dimensions

Configuration	Maximum Leaf Height (mm)	Maximum leaf Width (mm)
Single-Acting, Single-Leaf	2100	900

Table 2 – Intumescent Specification

Position	Intumescent Specification
Head	2 no. 10 mm wide by 2 mm thick (Palusol)
Vertical Edges	10 mm wide by 2 mm thick (Palusol)

Door Frame	130 mm by 30 mm hardwood (minimum density 750 kg/m ³) with 15 mm deep rebated stop
Hinges	Mild/stainless steel construction of blade dimensions 100 mm high by 30 mm wide bedded onto 2 mm thick graphite / Interdens intumescent material
Lockset	Mild steel tubular mortise latch referenced Dorma 711 bedded onto 2 mm thick graphite / Interdens intumescent material
Tolerances	All door leaves should be accurately fitted within the frame with an absolute maximum door gap (between the leaf and frame) of 3 mm

This Summary is based upon an a report, as referenced above, prepared by warringtonfire. Full details of the constructions and justification for the conclusions given, along with validity statements, are given in that report.

*The summary has been compiled between **warringtonfire** and **Al Huda Interiors**. It is intended to provide a brief outline of the above referenced report and not to replace it.*

Full copies of the referenced report may be obtained from:

Al Huda Interiors, Musafah 37, Plot No. 161, Industrial Area, Abu Dhabi, U.A.E.

Tel : +971 2 5515066

Fax : +971 2 5515065

Responsible Officer
S Hankey* - Technical Consultant

Approved
C W Miles* - Mid-East Product Listing Manager

* For and on behalf of warringtonfire.