

**Summary of Listing for warringtonfire – mideast
Listing No. 014**

Abanos Furniture Industries & Decoration '60 minute Doorsets'

Scope of Assessment

This Assessment Summary has been prepared by warringtonfire and is a summary of the Assessment report referenced below. Full details of the constructions, justification for the conclusions given, along with validity statements are given in that report and the supporting test report.

This summary sheet covers single-acting, single-leaf doorsets of a timber based construction as previously fire tested and assessed by warringtonfire to Clause 6 of BS 476: Part 22: 1987 'Methods for determination of the fire resistance of non-loadbearing elements of construction' up to the maximum sizes as shown.

The doorsets have been appraised for up to **60 minutes integrity & insulation**.

Assessment Report Reference

WF Report No. 151618

Period of Validity

Until 1st January 2011

Table 1: Maximum Door Leaf Dimensions

Doorset Configuration	Maximum Height (mm)	Maximum Width (mm)	Maximum Leaf Area (m²)
Single-Leaf, Single-Action, Latched	2264 (at 900 wide)	990 (at 2058 high)	2.04

This Assessment Summary is based upon an assessment report, as referenced above, prepared by warringtonfire. Full details of the constructions and justification for the conclusions given, along with validity statements, are given in the assessment report.

*This assessment summary has been compiled between **warringtonfire** and **Abanos Furniture Industries & Decoration**. It is intended to provide a brief outline of the above referenced assessment report and not to replace it.*

Full copies of the assessment may be obtained from:
Abanos Furniture Industries & Decoration, P.O. Box 6594, Sharjah, UAE
 Tel : + 971 6 5431638
 Fax : + 971 6 5432171

Responsible Officer

C Johnson* - Technical Consultant

Approved

C W Miles* - Mid-East Product Listing Manager

* For and on behalf of warringtonfire.