

CERTIFICATE OF APPROVAL
No. ME0116

This is to certify that the referenced products of

Faham International (F.Z.E)

P.O.Box 261471, St. 1241A, Jabal Ali Free Zone. Dubai, UAE.

Tel: ++(971) 4 8830633 Fax: ++(971) 4 8830383

Web:www.faham-international.com

have been assessed against the requirements of the *warringtonfire – mideast certification scheme* and are approved for use within the scope of the test and/or assessment report(s) referenced.

Timber Based FD60 Doorsets

**60 Minutes Integrity And Insulation Performances In Accordance With
Clause 6 Of BS 476: Part 22: 1987**

Report Reference	Valid Until
WF Test Report No. 172512 (Doorset A)	17 th June 2013
WF Assessment Report No. 174360	1 st July 2013

Approved Maximum Door Leaf Dimensions			
Configuration	Leaf Height (mm)	Leaf Width (mm)	Leaf Area (m ²)
FD60 Latched, Single-Acting, Single-Leaf, 54 mm thick	2646	1170	2.48

Intumescent Specification		
Intumescent Type	Intumescent Specification	Position
Exposed Intumescent Strips	2 off. 15 mm by 4 mm thick Mann McGowan Palusol PM	Two strips self adhered into a grooves, 7 mm apart, located within the rebate of vertical and head sections of the frame. One seal to be continuous and one seal interrupted at hinge positions. Seals trimmed around strike plate

CERTIFICATE OF APPROVAL

No. ME0116


Timber Based FD60 Doorsets

**60 Minutes Integrity And Insulation Performances In Accordance With
Clause 6 Of BS 476: Part 22: 1987**

Frame and Hardware Specification	
Door Frame	140 mm x 49 mm, with a 20 mm deep rebate (minimum density 650 kg/m ³)
Hinges	3off. Stainless steel construction of blade dimensions 101 mm high by 30 mm by 3 mm thick. Hinge blades to be bedded on 2 mm thick Interdens Type 15 sheet.
Lockset	Euro Elzet (Interdens Type 15, 2 mm thick, to be fitted around lock case and beneath strike plate. Also fitted behind handle plates)
Tolerances	All door leaves should be accurately fitted within the frame with an absolute maximum door gap (between the leaf and frame) of 3 mm.

Certification is awarded on the basis of initial type testing to BS 476: Part 22: 1987, initial inspection and ongoing surveillance of factory production control, and ongoing compliance with the scheme requirements including the use of labels supplied by warringtonfire. The currency of the certification may be verified at www.warringtonfire.net/mideast.

Signed for and on behalf of Warrington Certification



Sir Ken Knight
Chairman - Management Council

Issued: 30th June 2008
Valid to: 29th June 2013