

CERTIFICATE OF APPROVAL
No. ME0182

This is to certify that the referenced products of

Al-Hudebiya Engineering Co.

PO Box 42117, Shuwaikh, Postal Code 70652, Kuwait

Tel: +965 23261600 Fax: +965 23262100

Email: al_hudebiya@hotmail.com

have been assessed against the requirements of the *warringtonfire – mideast certification scheme* and are approved for use within the scope of the test and/or assessment report(s) referenced.

Al-Hudebiya Engineering Co. Steel Doorsets
180 Minutes Integrity Performance In Accordance With BS 476: Part 22: 1987

Assessment Report Reference	Valid Until
WF Test Report No. 183267	1 st July 2014
WF Assessment Report No. 184742	1 st August 2014

Doorset configuration	Maximum Height	Maximum Width	Leaf Thickness
Single-acting, Single-leaf, (Latched)	2086 mm	895 mm	45 mm

Doorset Construction	
Door Leaf	Door leaf briefly comprises 1.5 or 2 mm thick steel sheets folded around perimeter capping channels to all edges. Door leaves shall incorporate 3 no. internal stiffeners. Thickness of capping channels and stiffeners shall be identical to thickness of leaf skins. Mineral fibre core friction fitted within voids between stiffeners.
Door Frame	Double rebate, profiled steel. Steel thickness to suit that of leaf skins.
Hardware	Door hardware may be as tested under the reference WF Test Report No. 183267 or otherwise may be CERTIFIRE approved for use on steel doorsets for the required period.
Vision Panel	Vision panel having maximum sight dimensions equivalent to 0.065 m ² may be included. Vision panel may include Pyroshield Safety Clear glass for 90 minutes (bonded to beads using Autostic) or 60 minutes (not bonded). Alternatively CERTIFIRE approved glass types may be used.

CERTIFICATE OF APPROVAL
No. ME0182

Al-Hudebiya Engineering Co. Steel Doorsets

Certification is awarded on the basis of initial type testing to BS 476: Part 22: 1987, initial inspection and ongoing surveillance of factory production control, and ongoing compliance with the scheme requirements including the use of labels supplied by **warringtonfire**. The currency of the certification may be verified at www.warringtonfire.net/mideast.

Signed for and on behalf of Warrington Certification



Sir Ken Knight
Chairman - Management Council

Issued: 21st July 2009
Valid to: 20th July 2014