



CERTIFICATE OF APPROVAL
No CF 602

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

**FIRETHERM INTUMESCENT & INSULATION
SUPPLIES LIMITED**

**Unit F, Acorn Industrial Park, Crayford Rd, Crayford, Kent
DA1 4FT**

Tel: 01322 551010 Fax: 01322 552727

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT

Intusil Sealant

TECHNICAL SCHEDULE

**TS40 Linear Gap Sealing
Systems**

Signed and sealed for and on behalf of CERTIFIRE

Sir Ken Knight

Chairman - Management Council

Issued: 6th February 2008

Revised: 8th June 2009

Valid to: 5th February 2013

Page 1 of 4



Only valid when authentic
Seal is in place
CERTIFIRE



CERTIFICATE No CF 602
FIRETHERM LIMITED

Intusil Sealant

1. This approval relates to the use of Intusil Sealant for the fire protection of movement joints within walls and floors. The detailed scope is given in the Approval Matrix included in this Certificate. This shows the thickness for Intusil Sealant required to provide fire resistance periods in accordance with BS 476: Part 20: 1987 of up to 140 minutes for wall constructions.
2. This certification is designed to demonstrate compliance of the product or system specifically with Approved Document B (England and Wales), Section D of the Technical Standards (Scotland), Technical Booklet E (N. Ireland). If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.'
3. The product is approved on the basis of:
 - i) Initial type testing
 - ii) Audit testing at the frequency specified in TS40
 - iii) A design appraisal against TS40
 - iv) Inspection and surveillance of factory production control
 - v) Certification of quality management system to ISO 9001: 2000
3. The masonry, block or concrete walls and floors shall be at least 150mm thick and have at least the same fire rating as that required for the joint seal.
4. Masonry, block and concrete gap faces will be within the density range of 450 to 2300kg/m³, and gap faces will be free from loose or flaking material.
5. Backing or support materials may be polyethylene, polyurethane or polyurethane foam, mineral or ceramic fibre insulation.
6. The approval relates to ongoing production. Product and/or its immediate packaging is identified with the manufacturers' name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.

Further information regarding the details contained in this data sheet may be obtained from Firetherm Ltd (Tel: 01322 551010).

Further information regarding the CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).



CERTIFICATE No CF 602
FIRETHERM LIMITED

Intusil Sealant - Approval Matrix in Walls

Wall Installations in Vertical or Horizontal Orientation								
Product Name		Intusil Sealant						
Configuration	Max. Joint Width (mm)	Minimum Seal Depth (mm)	Backing Material	Integrity (mins)	Insulation (mins)			
Wall Constructions	Autoclaved aerated concrete/concrete/masonry/block	10	10	Polyethylene/polyurethane/mineral fibre/ceramic fibre 15 mm diameter/square (uncompressed)	140	140		
		15	15	Polyethylene/polyurethane/mineral fibre/ceramic fibre 20 mm diameter/square (uncompressed)				
		20	20	Polyethylene/polyurethane/mineral fibre/ceramic fibre 25 mm diameter/square (uncompressed)				
		25	25	Polyethylene/polyurethane/mineral fibre/ceramic fibre 30 mm diameter/square (uncompressed)				
		30	6	Stonewool (45kg/m ³) 25 mm deep			136	-
		100	6	Stonewool (45kg/m ³) 138 mm deep (may include butt joints)			120	120
Application Technique		For good adhesion the surfaces of the building element shall be free of any dust or grease and be suitably primed. The sealant may be applied to either face of the wall.						
Resistance to Smoke:		Not evaluated by this approval		Weather Capability:		Not evaluated by this approval		
Acoustic Rating:		Not evaluated by this approval		Movement Capability:		Not evaluated by this approval		



CERTIFICATE No CF 602
FIRETHERM LIMITED

Intusil Sealant - Approval Matrix in Floors

Floor Installations						
Product Name		Intusil Sealant				
Configuration		Max. Joint Width (mm)	Minimum Seal Depth (mm)	Backing Material	Integrity (mins)	Insulation (mins)
Floor Constructions	Autoclaved aerated concrete/concrete	110	6	Stonewool (45kg/m ³) 100 mm deep (may include butt joints)	120	120
Application Technique		For good adhesion the surfaces of the building element shall be free of any dust or grease and be suitably primed. The sealant is applied to the upper face of the floor.				
Resistance to Smoke:		Not evaluated by this approval		Weather Capability:	Not evaluated by this approval	
Acoustic Rating:		Not evaluated by this approval		Movement Capability:	Not evaluated by this approval	